



Replies to Pre-EOI Queries

06.07.2026

Name of Work:

Expression of Interest for Establishment of 22.7 MLD Capacity Tertiary Treatment Plant at Kavoor, Mangalore

EOI Document Ref. No: MSEZL/22.7MLD TTP/EOI/2026

No	Reference Clause	Tender Description	Bidder Query	MSEZL's Replies
EOI/Pg. No.5		14. Technical Design Basis	We understand that TTP plant shall be designed to handle the rated capacity of 22.7MLD with the given parameter range mentioned in point no.14 table, there is no need to consider additional parameter variation (stated in point no.16) on above values. Because it will directly impact on Capex as well as Opex of plant significantly. Kindly confirm.	The TTP Plant shall be designed for a maximum capacity of 22.7 MLD , as specified in the table under Point 14 .
		Parameter Unit Inlet		
		pH -		
		TSS mg/l		
		BOD mg/l		
		COD mg/l		
		Amm. Nitrogen mg/l		
		6.5 -7.5		
		30-50		
		20-40		
		16. Water quality variability considerations		
		Parameter Expected variation range		
		Flow		
		COD		
		TSS		
		Amm. Nitrogen		
		TDS		
		±25%		
		±20%		
		±20%		
		±20%		
		±15%		



[Signature]

No	Reference Clause	Tender Description	Bidder Query	MSEZL's Replies
4.		Design basis for plant operating hrs	We understand that plant shall be designed for 20 operating hrs for consistent reliability and availability of plant. Please confirm.	The plant shall be designed considering an operating duration of 20 hours per day.
5..		Site visit permission	We would like to visit the existing facility before EOI submission for better evaluation and understanding. Kindly allow the permission for the site visit.	Yes, you can visit the plant.

All other terms & conditions of the tender remain unchanged.


 Chief Executive Officer
 Mangalore SEZ Limited





